


AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT I D CODE		PAGE OF PAGES		
					1 3		
2. AMENDMENT/MOD NO. 2		3. EFFECTIVE DATE 8/20/2010		4. REQUISITION/PURCHASE REQ. NO. 4200324611		5. PROJECT NO.	
NASA Ames Research Center Acquisition Division Mailstop 213-13 Moffett Field, CA 94035-0001		CODE JAC		7. ADMINISTERED BY Ken Kitahara (650) 604-3717		CODE JAC-ANK	
8. NAME AND ADDRESS OF CONTRACTOR (No. Street, County, State and ZIP Code) ALL OFFERORS				(9)		9A. AMENDMENT OF SOLICITATION NO NNA10324611R	
				<input checked="" type="checkbox"/>		9B. DATED (SEE ITEM 11) 8/12/10	
				(10)		10A. MOD. OF CONTRACT/ORDER No	
CODE		FACILITY CODE		<input type="checkbox"/>		10B. DATED (SEE ITEM 13)	
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<p>The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers IS NOT extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:</p> <p>(a) By completing Items 8 and 15, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>							
12. ACCOUNTING AND APPROPRIATION DATA (if required)							
N/A Financial Management							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
<input type="checkbox"/> A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
<input type="checkbox"/> B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).							
<input type="checkbox"/> C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
<input type="checkbox"/> D. OTHER (Specify type of modification and authority)							
IMPORTANT: Contractor IS required to sign this document and return 1 copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
Subject: N233 Electrical Renovation							
This amendment provides the attached attendee lists for the site visits conducted on July 28 and August 18, 2010, and amendment to Sections. G.8 and L.17 of the RFP. All information provided during the visits is available in the drawings and specifications within the RFP. The last day for submittal of questions is August 23, 2010.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER			
				KENNETH KITAHARA			
15B. CONTRACTOR/OFFEROR				16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				 (Signature Of Contracting Officer)		Aug. 20, 2010	
NSN 7540-01-152-8070 PREVIOUS EDITION UNUSABLE				30-105		STANDARD FORM 30 (REV. 10-83) ES Prescribed by GSA FPMR (41 CFR)	

1. The list of attendees is attached (Refer to Attachment).
2. As a result of the construction site visit, the following answers are provided for the questions that were submitted.

Q1. The pictures posted on the drawings are very hard to review with any clarity or detail. Can the original JPEG files be made available for download and review?

A.1 The pictures will be provided as PDF files as part of the drawings.

Q2. Can you confirm that switchboard DPAA shown on drawing E3, sheet 3 is to be a new switchboard? It is marked as existing, but we do not see it shown on the existing equipment one-line drawings.

A.2 The main SWBD DPAA is new as shown on E10, E15, E24 and others.

Q3. Please verify the conductor sizes for the high voltage feeds to transformers T69 and T70.

A.3 Please refer to the feeders schedule as shown on E3, sheets 2 and 3 of 3 for the sizes.

Q.4 Can we submit past performance reviews that we have already received from public entities and email them directly to you or do you require that we use your form and have the entities send them directly to you?

A.4. No, the customer/public entity must forward the past performance reviews directly to NASA in accordance with the RFP.

Q.5 Once the past performance questionnaires have been submitted to you by September 3rd, how will we know if our proposal will be considered based on the Past Performance Questionnaires? Do you intend to email a notice of acceptance or denial?

A. 5 No communications regarding any submission or part of offerors' proposal package will made prior to the proposal due date.

3. Sections G.8 and L.17 are respectively changed to read as follows:

G.8 LIST OF GOVERNMENT-FURNISHED PROPERTY (NFS 1852.245-76) (OCT 1988)

(a) For performance of work under this contract, the Government will make available Government property identified below on a no-charge-for-use basis pursuant to the clause at FAR 52.245-1, Government Property. The Contractor shall use this property in the performance of this contract at the project site and at other location(s) as may be approved by the Contracting Officer. Under FAR 52.245-1, the Contractor is accountable for the identified property.

Item Description: Air handling unit, new relays, and power monitoring devices.

(End of clause)

**L.17 LIST OF AVAILABLE GOVERNMENT PROPERTY (NFS 1852.245-81) (DEVIATION)
(SEP 2007)**

(a) The Government will make the following Government property available for use in performance of the contract resulting from this solicitation, on a no-charge-for-use basis in accordance with FAR 52.245-1, Government Property. This property must be used on the contract as shown in the plans and specification.

Item Description: Air handling unit, new relays, and power monitoring devices.

(b) The selected Contractor will be responsible for costs associated with transportation and installation of the property listed in this provision.

(End of provision)

4. All other general information provided during the visits are available in the drawings and specifications within the RFP.
5. The last day for submittal of questions is August 23, 2010.

End of Amendment Two (2)
Nothing Follows

N233 ELECTRICAL RENOVATION

SITE VISIT ATTENDANCE

Please Print

Name	Organization	Phone Number	Email
Ken Kitahara	NASA	(650) 604-3717	kenneth.kitahara@nasa.gov
ED PAULINO	EATON	(925) 321-7521	Edward.F.Paulino@eaton.com
JASON CROWSON	EATON	(916) 934-6383	JASONDCROWSON@EATON.COM
SAM TEHRANI	DWG & ASSOCIATES	(805) 588-1189	Sam@dwg1.com
JERRY RASMUSSEN	General Equipment	(667) 444-4444	Jerry.R@GeneralEquipment.com

N233 ELECTRICAL RENOVATION SITE VISIT

Aug. 13, 2010

Name	Organization	Phone Number	Email
DONG TRAN	NASA	40898	Pong.T.TRAN@NASA.GOV ✓
ED PAULLINO	EATON CORP	925-321-7821	Edward.F.Paulino@eaton.com
DAVID PINEO	ROSENDIN	408-793-5098	dpineo@rosendin.com
Ali Vakili	EATON	925-454-3724	Ali.Vakili@Eaton.com
Wes FRANKS	ROYAL	916-226-7251	WesF@RoyalElecT.com
TIMOTHY MARTIN	SYSKA HENNESSY	650-288-5391	TMARTIN@GKKWORKS.COM
LINDA TUTTLE (FOR JOE PECOTA)	CONTRA COSTA Elec	925-229-4250	JOE_PECOTA@EMCORGROUP.COM
MICHAEL Williams	Systems Electric	650-428-1900	Mike@SystemsElec.com
.			
	-		